



City of McCall

CITY CLERK

www.mccall.id.us

216 East Park Street
McCall, Idaho 83638

Phone 208-634-7142

Fax 208-634-3038

Fire Safety Guidelines

1. A fire extinguisher with a minimum rating of 2A:40B:C should be installed in a readily accessible and visible location on the business premises and inspected by a qualified technician within the last 12 months (other fire/safety requirements may be needed).
2. Electrical circuit breakers should be labeled for the electrical equipment they control.
3. Exit doors and corridors should be kept free and clear of obstructions or locking devices which require special keys, tools, or knowledge to operate during business hours.
4. Smoke and carbon monoxide detectors are required for commercial and residential buildings with fuel burning appliances.

Please contact the McCall Fire District for more info or questions concerning safety requirements at (208) 634-7070.