



NOTES:

1. CLEAN VALVE BOX OF ALL DEBRIS AND SOIL.
2. ALL VALVE BOX LIDS TO BE 5 1/4" DROP LIDS. ALL WATER VALVE BOX LIDS TO BE STAMPED "WATER" AND ALL FIRE VALVE BOX LIDS TO BE STAMPED "FIRE".
3. FOR ASPHALT SURFACE, CONCRETE COLLAR TO BE 1/4" BELOW FINISHED GRADE.
4. FOR GRAVEL ROADWAY SURFACE, CONCRETE COLLAR TO BE 4" BELOW FINISHED GRADE AND SLOPED AWAY FROM VALVE BOX LID SO THAT OUTSIDE EDGE IS 1" LOWER.
5. VALVE BOXES OUTSIDE OF PAVED OR GRAVEL ROADWAYS SHALL HAVE A CONCRETE COLLAR POURED TO BE FLUSH WITH FINISHED GRADE.
6. DRILL 7/8" HOLE IN TOP PORTION OF VALVE BOX. PLACE PCV VALVE GROMMET INTO HOLE AND ROUTE TRACER WIRE THROUGH HOLE.
7. TYLER UNION CAST IRON RISER IS NOT TO BE USED WITHIN STATE HIGHWAYS. ONLY FOR USE WITHIN CITY OF McCALL ROADWAYS.
8. REFER TO KUPFERLE TRUFLO #TF500 BLOW-OFF SPECIFICATIONS FOR ADDITIONAL INFORMATION



PUBLIC WORKS DEPARTMENT
 815 N. SAMSON TRAIL
 McCALL, IDAHO 83638
 208.634.5580

CITY OF McCALL
 4" BLOW-OFF ASSEMBLY

STANDARD DRAWING NO.

MSD-405

PROJECT		DRAWN BY	SHEET NO.
DATE	1/12/2023		1 OF 1