


NOTES:

1. COMPACTION AND TESTING FOR ALL AGGREGATE BASE/SUBBASE MATERIAL SHALL BE IN ACCORDANCE WITH ISPWC 802.
2. ASPHALT FOUR (4") INCHES IN THICKNESS SHALL BE PLACED IN TWO (2") INCH LIFTS.
3. GEOTEXTILE FABRIC TO EXTEND 2' MIN. BEYOND THE EDGE OF ASPHALT. ALL SEAMS TO OVERLAP 2' MIN.
4. COMPACTION AND TESTING FOR ALL HOT MIX ASPHALT SHALL BE IN ACCORDANCE WITH ISPWC SECTION 810 AND PROJECT PLANS AND SPECIFICATIONS.
5. ALL CONCRETE CURBS SHALL BE ISPWC TYPE II CURB AND GUTTER. CONCRETE MIX DESIGN TO BE CLASS 4000A WITH 3/4" AGGREGATE IN ACCORDANCE WITH ISPWC SECTION 703, CAST-IN-PLACE CONCRETE, TABLE 1. ALL OTHER CONCRETE (I.E. SIDEWALK, APPROACHES AND RAMPS) TO BE CLASS 4000B WITH 3/4" AGGREGATE IN ACCORDANCE WITH ISPWC SECTION 703, CAST-IN-PLACE CONCRETE, TABLE 1. SILANE-40 CONCRETE SEALER REQUIRED.
6. MICRO-SYNTHETIC FIBERS SHALL BE FIBERMESH OR APPROVED EQUIVALENT. LENGTH OF FIBERS SHALL BE AS RECOMMENDED BY THE MANUFACTURER. ADD 1.5 POUNDS OF FIBERMESH OR APPROVED EQUIVALENT PER CUBIC YARD OF CONCRETE, OR AS RECOMMENDED BY MANUFACTURER.
7. REVEGETATE ALL DISTURBED AREAS WITH A CITY APPROVED GRASS MIXTURE OVER FOUR (4") INCHES OF TOPSOIL, PER APPROVED LANDSCAPING PLAN, OR AS INDICATED WITHIN THE PLANS.

 City of McCall <small>PUBLIC WORKS</small>	PUBLIC WORKS DEPARTMENT 815 N. SAMSON TRAIL McCALL, IDAHO 83638 208.634.5580	CITY OF McCALL			STANDARD DRAWING NO. MSD-801A
		TYPICAL ROADWAY SECTION - ARTERIAL URBAN			
		PROJECT	DRAWN BY	SHEET NO.	
		DATE	1/12/2023	1 OF 1	