

CITY OF MCCALL
VALLEY COUNTY, IDAHO
STANDARD REVISIONS TO THE 2020 ISPWC AND SUPPLEMENTAL CONDITIONS

DIVISION 300 – TRENCHING

SECTION 303 – EXPLORATORY EXCAVATION

PART 1 – GENERAL

Amend Part 1.4 to include the following:

- D. Submit pipe bedding material as required by Section 305 – Pipe Bedding.
- E. Submit Controlled Density Fill Mix design per ITD Standard Specifications for Highway Construction Section 522.
- F. Submit all other materials to be used in backfilling and surface restoration.

PART 2 – MATERIALS

Amend Part 2.1 to include the following:

- D. For exploratory excavation and potholing within asphalt surfaces in the City of McCall ROW, a minimum of 12” of Type III bedding material per ISPWC Section 305.2.4 is required to be used above the exposed utility.
- E. For exploratory excavation and potholing within asphalt surfaces in the City of McCall ROW, Controlled Density Fill is required to be installed above the Type III bedding material to the bottom of the existing asphalt surface (Match existing asphalt thickness or 3” minimum, whichever is greater).
- F. For exploratory excavation and potholing within gravel surfaces in the City of McCall ROW, Type III bedding material per ISPWC Section 305.2.4 is required to be used above the exposed utility to within 12” of the finished grade.
- G. For exploratory excavation and potholing within gravel surfaces in the City of McCall ROW, Type I crushed aggregate for base material per ISPWC Section 802.2.A, Table 1, is required to be used within 12” of the finished grade and compacted to within 95% of the standard proctor.
- H. For exploratory excavation and potholing within vegetated swales and non-gravel or asphalt surfaces in the City of McCall ROW, Type III bedding material per ISPWC Section 305.2.4 is required to be used above the exposed utility to within 4” of the finished grade. Place 4” of topsoil at finished grade and re-vegetate with native drought tolerant grass seed mixture or repair surface to previous conditions or better.

CITY OF MCCALL
VALLEY COUNTY, IDAHO
STANDARD REVISIONS TO THE 2020 ISPWC AND SUPPLEMENTAL CONDITIONS

PART 3 – WORKMANSHIP

Modify part 3.1.E to the following:

Excavate, backfill, and restore surfacing in accordance with City of McCall Standard Revisions to the ISPWC, City of McCall Standard Details, and applicable sections of the ISPWC in addition to the following:

1. For exploratory excavation and potholing within asphalt surfaces in the City of McCall ROW, sawcut existing asphalt in a clean and square fashion to a minimum of 12" beyond the excavation limits and overlay new asphalt on top of undisturbed existing base material. Asphalt used shall be HMA and shall match the existing type, specifications, and depth of asphalt used within the roadway or a minimum of 3" thickness, whichever is greater.
2. For exploratory excavation and potholing within gravel surfaces in the City of McCall ROW, excavate a minimum of 12" beyond the exploratory excavation limits to a depth of 12", install Type I crushed aggregate for base material per ISPWC Section 802.2.A, Table 1, and compact to within 95% of the standard proctor.